



Ref. Certif. No.

SE-96028

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR
ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Moulded Case Circuit Breakers

Name and address of the applicant

Wenzhou Aoelec Electrical Co., Ltd.
No. 7, Zhenxing road, Xinguang Industrial Zone, Liushi Yueqing,
Zhejiang, CHINA

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

See page 2

Trademark (if any)

Aoelec

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

AUB2

Additional information (if necessary may also be
reported on page 2)

-

A sample of the product was tested and found
to be in conformity with

IEC 60947-2:2016

As shown in the Test Report Ref. No. which forms part
of this Certificate

190801555SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 5 November 2019

intertek

Signature:


Henrik Wikström



Ref. Certif. No.

SE-96028

Ratings and principal characteristics

$U_n = 240V\sim(1P), 415V\sim(2, 3, 4P), 50/60Hz$

$I_n = 63, 80, 100, 125A$

$I_{cu} = 10kA, I_{cs} = 7,5kA, U_i = 690V\sim, U_{imp} = 4kV$

Utilization category: A

The fourth pole is identical with phase pole

Date: 5 November 2019

Signature: