

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Circuit-breakers for overcurrent protection

Name and address of the applicant

Wenzhou Aoelec Electrical Co., Ltd.
No. 7, Zhenxing road, Xinguang Industrial Zone, Liushi Yueqing
Zhejiang China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

See page 2

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

AUB1

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

200801377SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Signature:



Leif Mattsson

Date: 27 October, 2020

Ratings and principal characteristics

$U_e=240/415V\sim(230/400V\sim)$ for 1P, $240V\sim(230V\sim)$ for 1P+N,
 $415V\sim(400V\sim)$ for 2P, 3P, 3P+N, 4P

$I_n=3, 4, 6, 10, 13, 16, 20, 25, 32, 40, 45, 50, 63A$ (1P)

$I_n=6, 10, 16, 20, 25, 32, 40, 50, 63A$ (2P, 1P+N, 3P, 3P+N, 4P)

$I_{cs}=I_{cn}=6000A$, B- and C- type

Date: 27 October, 2020

Signature:

A handwritten signature in blue ink, appearing to read 'J. Matthe', is written over a light blue horizontal line.