



Ref. Certif. No.

**SE-93436**

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**

**CB TEST CERTIFICATE**

Product

Circuit-breakers with overcurrent protection

Name and address of the applicant

Wenzhou Aoelec Electrical Co., Ltd.  
No. 7, Zhenxing Road, Xinguang Industrial Zone, Liushi,  
Yueqing, Zhejiang, China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

*Note: When more than one factory, please report on page 2*

Same as applicant

Ratings and principal characteristics

Ue= 240/415V~(1P), 240V~(1P+N), 415V~(2, 3, 3P+N, 4P)  
In= 1, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63A  
Ics=6kA, Icn=6kA; B-, C-, D- type;  
Energy limiting class: 3 (Only B-, C- type)

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

HBE

Additional information (if necessary may also be reported on page 2)

The interrupted protected neutral pole is identical with phase pole.

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

190102229SHA-001

This CB Test Certificate is issued by the National Certification Body

**Intertek Semko AB**  
Box 1103  
SE-164 22 Kista, Sweden  
Int +46 8 750 00 00

Date: 1 March 2019

**intertek**

Signature:

Henrik Wikström